



## OFFICE OF THE ASST. FIRE OFFICER, SUNDARGARH FIRE STATION

L.No- 3526/ SNG FS,

Dt.29.06.2021

To,

**The Principal/ Headmaster Ekalabya Model Residential School,  
Bhabanipur, Dist- Sundargarh.**

Sub- Provision of required Fire prevention and Fire safety measures in your premise/ occupancy.  
Sir,

With reference to the subject cited above, it is bring to your kind notice that the aforementioned premise/occupancy is covered under Rule 9 (1) of Odisha fire prevention and fire Safety Rules, 2017 and amendment rule 2019 is likely to have risk of fire, which may lead to loss of life or property in case of any outbreak of fire.

As per Rules- 11 of Odisha Fire prevention and fire Safety Rules, 2017 you are required to obtain valid fire safety certificate. Moreover, as per Rule 11(2) of Odisha Fire prevention and fire safety Rules, 2017, you are requested not to allow any occupancy till fire safety certificate is obtained.

Hence, adequate fire prevention and fire safety measures should immediately be installed in your premise/ occupancy for safety of life and property.

Further, as per provision of Rules-13 (1) of Odisha fire prevention and fire safety Rules, 2017, you are requested to apply (on line/ off line)in form-III (available in [www.odishafshgscd.gov.in](http://www.odishafshgscd.gov.in) / [www.agnishamaseva.odisha.gov.in](http://www.agnishamaseva.odisha.gov.in) ) indicating measurements of all structural components along with self attested copies of all relevant documents mentioned therein without any delay . Besides, as per Rule 13 (1) and 14 (2) of Odisha fire prevention and fire safety Rules, 2017, you are also required to deposit fees as applicable in Govt. account under head "**0070-OAS-60- Other Receipts- 109-Fire Protection & control - 0097 Misc. Receipts-02082- Miscellaneous other Receipts**" in shape of treasury challan/ copy of e.challan should be enclosed along with your application.

In case of failure to obtained fire safety certificate within the time limit necessary appropriate legal action may be initiated against you.

It is therefore requested that necessary fire safety measures may be provided in the building within prescribed time limit and apply to the authority competent for obtaining fire safety certificate.

Yours faithfully,

Asst. fire Officer

Sundargarh Fire station  
**Asst. Fire Officer**

**Sundargarh Fire Station**


Memo No- /SNG Fs. Dt.

Copy submitted to the collector Sundargarh for favour of information and necessary action.

Asst. Fire officer  
Sundargarh Fire Station

**The Following Fire Fighting Installations Are Required In Your School And  
Hostel Premises**

01. First aid hose reel hose
02. fire extinguishers ABC Type & CO2 Type
03. Terrace tank 10,000 ltrs. capacity
04. Terrace pump
05. Public alarm system
06. Lighting arrester above the building
07. Auto Mode DG Set.
08. Sign Ways



Asst. Fire Officer  
Sundargarh Fire Station

7/24/2021

<https://www.agnishamaseva.odisha.gov.in/Firesafety/FiresafetyFormReceipt/1174/Firesafety>

## Receipt - 1



### PAYMENT ACKNOWLEDGEMENT

**Payment Successful**

Receipt No : 981/2021

Application No FSC1307230012021000768

Transaction Date & Time 24-07-2021 20:58:12

Challan Referen : 311024427A

Status Success

Amount (in INR) 6503

*Sanigrahi*  
26.7.21  
Principal  
EMRS, Bhawanipur  
Sundergarh