



B

mail: eerwss_kld@nic.in
eerwsskld@gmail.com
Phone No: 06670-230784

**OFFICE OF THE SUPERINTENDING ENGINEER,
KALAHANDI RWS&S DIVISION, BHAWANIPATNA**

Letter No.

3374

/Dated/

30.05.2023

To

The District Welfare Officer,
Bhawanipatna, Kalahandi


Sub - Safe drinking water and sanitary condition Certificate .
Ref: - Your Letter:1037 Date:-10/05/2023

Sir,

With reference to above , the Safe drinking water and sanitary condition Certificate of enclosed herewith for your information & necessary action .


Encl: - As Above.

Yours faithfully,


Superintending Engineer,
Kalahandi RWS&S Division,
Bhawanipatna

Memo No. 3375 /dt. 30.05.2023

1. Copy submitted to the Ekalavya Model Residential School, Dhanrabhata, At: Dhanrabhata Po: Biswanathpur Dist: Kalahandi for favour of kind information.


Superintending Engineer,
Kalahandi RWS&S Division,
Bhawanipatna

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

Certified that an inspection team headed by **Assistant Engineer, RWS&S Section Lanjigarh**, (Name of officer with designation) from Kalahandi RWS&S Division, Bhawanipatna. (Name of Department/Office) inspected the **Ekalavya Model Residential School, Dhanrabhata, Biswanathpur, Kalahandi**. (Name and Address of the School) on **26.05.2023** and found that **Ekalavya Model Residential School, Dhanrabhata** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribe by the central/state/U.T. GOVT.

The above valid for a period of One Year.

Signature with seal:

Name:

Designation:

Ajay Kumar Mishra
30/5/23
Superintending Engineer
Kalahandi RWS&S Division
Bhawanipatna
Superintending Engineer.

To

Ekalavya Model Residential School,

At: Dhanrabhata, Biswanathpur

Dist: Kalahandi

(Name & Address of the Institution)

WATER SAMPLE TESTING REPORT

District Water Testing Laboratory, Kalahandi RWS&S Division, Bhawanipatna

Sl. No.	Name of the Block	Name of the Grampanchayat	Name of the Village	Name of Habitation	Source	Temperature	Chloride (mg/L)	Total Alkalinity mg/L (as CaCo3)	Total Hardness mg/L (as CaCo3)	pH	Turbidity (NTU)	Fluoride mg/L (as F)	TDS (mg/L)	Iron (mg/L)	E coli
1	Lanjigarh	Biswanathpur	Dhanrabhata	EMRS,Dhanrabhata	T/W	25.5	72	276	312	7.47	1.59	0.46	673.6	0.845	Absent
Remarks: Water Sample Collected by EMRS, School Staff															
							250 to 1000 (mg/L)	200 to 600 mg/L (as CaCo3)	200 to 600 mg/L (as CaCo3)	6.5 to 8.5 pH	1.0 to 5.00 (NTU)	1.0 to 1.50 (mg/L)	500 to 2000 mg/L	1.0 (mg/L)	Absent

S. S. Jena
30-05-2023
Lab Chemist

District Water Testing Laboratory
Kalahandi RWS&S Division,
Bhawanipatna

Jahnvi 30/05/23
Superintending Engineer,
Kalahandi RWS&S Division,
Bhawanipatna