

FIRE SAFETY CERTIFICATE

Certified that Ekalabya Model Residential School, Ranki, Keonjhar has inspected and found the following:

1. A R D road is approaching to the school.
2. The school is functioning in G+1 floor building.
3. Each class room of the school building has one doorway.
4. The doorway opening inwardly fitted with double swing. There is a staircase for evacuation of children from 1st floor of building to safe area in the shortest possible time.
5. No any structure has been constructed by thatch or other combustible material inside the school building or adjoining to school.
6. The school is free from highly inflammable and toxic materials.
7. Cooking area is situated at a safe place away from the building where students are located for education.
8. The management has installed 4 nos D.C.P fire extinguisher in different places in the school building to meet any fire situation. Besides, adequate fire safety measures have been taken in the hostel premises for safety of the occupants.

This office has no objection towards fire safety point of view to the School and Hostel building.



12.2.14

Assistant Fire officer
Keonjhar Fire Station
Keonjhar Fire Station
Dtd. 12.02.2014

Memo. 714 /KNI FS

Copy to the Principal, Ekalabya Model Residential School, Ranki, Keonjhar for information with reference to his letter no-44/EIMRS/14 dtd.22.01.2014



12.2.14

Assistant Fire officer
Keonjhar Fire Station
Assistant Fire Officer
Keonjhar Fire Station