

OFFICE OF THE DEPUTYFIRE OFFICER, SAMBALPUR CIRCLE, SAMBALPUR

E-mail- dfosbpcircle@gmail.com

FORM-V FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. 10/2021/SBP (CRL) FP

Certificate No. 06/2021/SBP (CRL) FP

Dated 16.09 2021

This Certificate is valid up to Two years from the date of issue.

(Apply for renewal at least three months before expiry)

Certified that Academic & Administrative Building of Ekalavya Model Residential School, Kuchinda, over Plot No. 1151, Khata no. 90, Mouza- Kundaposhi, At/Po- Kuchinda, Dist- Sambalpur consisting of total one number of Block was inspected by officers of the Fire Service on 13.08.2021 & 15.09.2021 in presence of Sri Chakradhar Majhi, Principal and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 and that its various floors are fit for occupancy or usage as noted here under against each subject to compliance to the conditions as prescribed herein below.

1.	G+1 floor	Usage	Educational
	(Academic & Administrative Building)		

CONDITIONS:

- 1. Fire prevention and safety measures and appliances, availability of water supplies and means of access in thereto etc provided in the building or premises, should be maintained by the occupier (s) in best irrepairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
- 2. The set-backs, driveways, entrance gates, exits, corridors and escape ways should not be changed, obstructed or modified in any way.
- 3. The occupier (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
- 4. Fire drills/rehearsals should be organized at least once in six months by involving Local Fire Stations.
- 5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Towers/ Blocks of building/premises.

By order of the Director of Fire Service

Signature with seal

Name and Designation of Issuing Authority

(Rangadhar Acharya)
Deputy Fire Officer,
Sambalpur Circle, Sambalpur

Memo No. 418 /SBP (CRL)

Dtd.16/09/2021

Copy to the Sri Chakradhar Majhi, Principal Ekalavya Model Residential School, Kuchinda, At/Po- Kuchinda, Dist- Sambalpur with additional conditions as mentioned below for kind information & necessary action.

Additional Conditions

- 1. Failure of proper maintenance & non-functional of firefighting gadgets at the time of emergency shall be the responsibility of the occupier/ management. However test checked the fixed Fire Fighting installations and found functioning properly as on date of re-inspection i.e 15.09.2021.
- 2. Good housekeeping both inside and outside should be maintained throughout and there must not be any laxity in this regards.
- 3. The managements shall provide any additional fire safety requirements, in future, if issued from time by this department.
- 4. All electrical installations must be periodically checked and tested by competent electrical engineers. All those electrical wiring if any shall be replaced immediately. Electrical safety audit should be carried out at regular interval as per Indian electrical Rules.
- 5. No Smoking Zone should be enforced rigidly.
- 6. Trained staff in dealing with firefighting extinguishers/ appliances/ Evacuation procedure should be engaged.
- 7. Neither there shall be any addition or alternation nor any change in occupancy or usage to this existing building or part thereof.

Deputy Pire Officer, Sambalpur Circle, Sambalpur

~ 2 ~